

Project No. O501-10618/O513-10619

ADDENDUM NUMBER 2

WAR MEMORIAL NORTH ENTRANCE RENOVATION RE-BID AND NORTH PARKING LOT  
Site #265, Bldg. #40  
750 N. Lincoln Memorial Drive  
Milwaukee, WI 53202

Project Number: O501-10618/O513-10619

Date of Addendum: September 24, 2010

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated September 8, 2010, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

CHANGES TO BIDDING REQUIREMENTS:

1. **DOCUMENT 00400 BID FORM; REVISE** date of COMMENCEMENT AND COMPLETION OF CONTRACT WORK to June 1, 2011.

CHANGES TO CONDITIONS OF THE CONTRACT:

1. None

CHANGES TO SPECIFICATIONS (DIVISIONS 2 THRU 33):

1. **Section 08 41 13 ALUMINUM-FRAMED ENTRANCES AND STOREFRONTS; REVISE** 2.5, A. 1. as follows:
  1. **REVISE** extruded-aluminum tubular rail and stile wall thickness from 0.188-inch to 0.125-inch overall thickness.
  2. **Section 08 71 13 AUTOMATIC DOOR OPERATORS; ADD** to 2.01, A. Manufacturer: 8. Tormax Technologies, Inc.
  3. **Section 11 12 00 PARKING EQUIPMENT**
    1. **REVISE** 2.1, C. "*Approved*" manufacturer to "*Basis of design, quality standard*" manufacturer is Par-Kut International, Inc.
    2. **REVISE** 2.1, D. Products as follows: Pre-assembled booth unit(s) shall be Model 75HC CENTRY, ADA compliant.
    3. **ADD** to 2.1, D. 14. Air conditioner: Coleman RV Roughneck 7433 Series. 115V 60 Cycles 1 Phase, 13,500 BTU capacity.

CHANGES TO DRAWINGS:

All drawing revisions occur to the "NORTH PARKING LOT" drawing set.

1. **Sheet S111 CANOPY FRAMING PLAN;**
  1. **REVISE** note reference reading "SEE 3/S111" to read "SEE 3/S101".

ATTACHMENTS: NONE.

End of Addendum No. 2